

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-0026:213 Page 1 of 1

CATEGORY: Control Units (Non High-Rise)

LISTEE: Simplex, 100 Simplex Drive, Westminster, MA 01441-0001
Contact: Paul Mattern (978) 731-8542 *Fax (978) 731-8881

DESIGN: Model 4004-9101, 9102, -9201 and -9202 fire alarm control units. Power-limited, coded, non-coded, local, local, auxiliary, remote station, proprietary and central station fire alarm service; automatic, manual and waterflow alarm and sprinkler supervisory service. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

565-573	System Board
4004-9802, -9804, -9822, -9824	Initiating Expander Board
4004-9806	Style Z Adapter
4004-9809, -9829	City Connect Board
4004-9808	Annunciator Interface Board
2080-9044	DACT
4004-9810	DACT
2088-9007	Shunt Module

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire control units for use with separately listed compatible initiating and indicating devices.

The control units can generate the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition. Refer to listee's Installation Instruction Manual for details.

NOTE: For **Fire Alarm Verification Feature**, the maximum Retard/Reset/Restart must be adjusted to 30 sec. or less.

*Rev. 05-13-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

MAY 13, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager